

## NOTICE REGARDING YOUR DRINKING WATER

**August 31, 2016**

Quarterly results related to chlorine by-products have been received for the third quarter of 2016.

Please note that the Township of Bloomfield is now **IN COMPLIANCE** with the Chlorine By-Product Rule and there will be no further notices released related to this issue of non-compliance.

The following is a summary of the running average for chlorine by-products at all sampling and test sites:

Required Running Quarterly Average for TTHM  $\leq$  0.080 mg/L or 80  $\mu$ g/L (Trihalomethanes)

Site ID	Location	Fourth Quarter November 2015 ( $\mu$ g/L)	First Quarter February 2016 ( $\mu$ g/L)	Second Quarter May 2016 ( $\mu$ g/L)	Third Quarter Aug. 2016 ( $\mu$ g/L)	Running Annual Average ( $\mu$ g/L)
1	61 Bukowski Place	90	59	66	82	74
2	1409 Broad Street	70	48	65	68	63
3	127 Evans Road	91	56	72	74	73
4	25 Daka Court/321 Broughton Ave	84	56	50	67	64

HAA<sub>5</sub> Results:.

Required Running Quarterly Average for HAA<sub>5</sub>  $\leq$  0.060 mg/L or 60  $\mu$ g/L (Haloacetic Acids)

Site ID	Location	Fourth Quarter November 2015 ( $\mu$ g/L)	First Quarter February 2016 ( $\mu$ g/L)	Second Quarter May 2016 ( $\mu$ g/L)	Third Quarter Aug. 2016 ( $\mu$ g/L)	Running Annual Average ( $\mu$ g/L)
1	61 Bukowski Place	38	61	44	34	44
2	1409 Broad Street	57	51	57	68	58
3	127 Evans Road	42	65	55	67	57
4	25 Daka Court/321 Broughton Ave.	59	54	54	64	58