

SUMMARY INTERIM AND SPECIAL SAMPLING FOR CHLORINE BY-PRODUCTS

November 17, 2016

TTHM ≤ 0.080 mg/L or 80 µg/L

Site ID	Location	First Quarter February 2016 (µg/L)	Interim March 2016 (µg/L)	Interim April 2016 (µg/L)	Second Quarter May 2016 (µg/L)	Interim June/July 2016 (µg/L)	Interim July 2016 (µg/L)	Third Quarter Aug. 2016 (µg/L)	Interim Sept. 2016 (µg/L)	Interim Oct. 2016 (µg/L)
1	61 Bukowski Place	59	71	78	66	67	66	82	90	73
2	1409 Broad Street	48	59	64	65	52	47	68	76	57
3	127 Evans Road	56	58	82	72	55	55	74	77	69
4	25 Daka Court/321 Broughton Ave	56	61	61	50	51	52	67	81	56
5	40 Bukowski Place (Special Sample)			84	74	72	64	74	84	71
SPECIAL SAMPLES NEAR INTERCONNECTIONS										
	190 Grove Street/136 Bloomfield Ave	49	53	77	74	49	58	82	79	75
	586 Bloomfield Avenue	49	54	62	39	69	70	72	70	66
	151 West Passaic Avenue	47	63	60	37	No access	37	No access	No access	43

HAA₅ Results:.

HAA₅ ≤ 0.060 mg/L or 60 µg/L

Site ID	Location	First Quarter February 2016 (µg/L)	Interim March 2016 (µg/L)	Interim April 2016 (µg/L)	Second Quarter May 2016 (µg/L)	Interim June/July 2016 (µg/L)	Interim July 2016 (µg/L)	Third Quarter Aug. 2016 (µg/L)	Interim Sept. 2016 (µg/L)	Interim Oct. 2016 (µg/L)
1	61 Bukowski Place	61	41	40	44	33	31	34	16	30
2	1409 Broad Street	51	51	40	57	44	51	68	51	37
3	127 Evans Road	65	40	51	55	52	58	67	66	37
4	25 Daka Court/321 Broughton Ave.	54	45	36	54	48	64	58	54	35
5	40 Bukowski Place (Special Sample)			45	48	30	37	49	25	29
SPECIAL SAMPLES NEAR INTERCONNECTIONS										
	190 Grove Street/136 Bloomfield Ave	44	49	41	52	46	52	61	47	64
	586 Bloomfield Avenue	44	61	34	39	68	72	66	54	39
	151 West Passaic Avenue	51	41	33	33	No access	No access	No access	No access	25