

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/9/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
1	5552	Sylvan Road and Barnett			
2	5553	215 Sylvan Road			
3	5554	Sylvan Road and Bolton Place			
4	5551	Sylvan Road and Craig Place			
5	5226	1255 Broad Street			
6	5227	1271 Broad Street - Convenience Store			
7	5131	1293 Broad Steet - Office Bldg			
8	5137	1332 Broad Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/10/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
9	5429	Broad St. - Between Broadacres Dr. & Shoprite Exit			
10	5141	Broad Street in front of Shoprite Parking Lot			
11	5431	Broad St. Between Broadacres Dr. North & South Int.			
12	5432	1515 Brad Street North of Entrance			
13	5436	1515 Broad Steet - North of Employee Entrance			
14	5442	2 Foster Street			
15	5223	1242 Broad Street by Brookdale School			
16	5215	1207 Broad Street near Morley Lane			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/11/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
17	5201	1087-1091 Broad Street			
18	4509	1059 Broad Street			
19	4508	1044 Broad Street			
20	4507	1012 Broad Street			
21	4506	987 Broad Street			
22	4504	947 Broad Street			
23	4503	924 Broad Street			
24	4502	Fairway Gardens - East Side of Broad Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/12/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
25	4501	Glen Ridge Country Club -West Side of Broad Street			
26	4208	Glen Ridge Gardens - Opposite Sunset Avenue			
27	4206	839 Broad Street			
28	4205	834 Broad Street			
29	4204	797 Broad Street			
30	4203	794 Broad Street			
31	4202	755 Broad Street			
32	3411	712-714 Broad Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/13/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
33	3412	711 Broad Street			
34	3410	660-666 Broad Street			
35	3409	653-661 Broad Street			
36	3408	606-612 Broad Street			
37	3407	577 Broad Street			
38	3404	548 Broad Street			
39	3246	424 Broad Street			
40	3240	300 Broad Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/14/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
41	2225	186 Broad Street			
42	2234	160 Broad Street			
43	2259	94 Broad Street			
44	5329	659 East Passaic Avenue			
45	5330	625 East Passaic Avenue			
46	5331	595 East Passaic Avenue			
47	4738	127 Watchung Avenue			
48	4736	591 Broughton Avenue			

**LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/15/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
49	4723	500 Broughton Avenue			
50	4704	404 Broughton Avenue			
51	4611	336 Broughton Avenue			
52	4608	298 Broughton Avenue			
53	4601	242 Broughton Avenue			
54	4332	205 Broughton Avenue			
55	4316	135 Broughton Avenue			
56	3437	75 Broughton Avenue			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/16/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
57	3434	Bay & Broughton - northeast corner - church			
58	3430	55 Bay Avenue			
59	3405	543 Broad Street (in Brookside Park)			
60	3445	Hoover Avenue at Chapel Street			
61	3523	145 North Spring Street			
62	3524	121 North Spring Street			
63	3526	97-99 North Spring Street			
64	3222	55 North Spring Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/17/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
65	3223	178 Baldwin Street			
66	3210	39 Spring Street			
67	3208	47 Division Street			
68	3204	Spring Street at East Almira			
69	3202	85 Spring Street			
70	3201	Spring Street at Apartment Entrance			
71	2217	Kennedy Drive (Front of Memorial Park Tennis Courts)			
72	2216	Kennedy Drive (Essex House Apartments)			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/18/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
73	2241	307 Belleville Avenue			
74	2274	Rosewood Terrace - End of Cul-de-Sac			DEAD END
75	2319	98 Woodland Road			
76	2318	70 Woodland Road			
77	2317	43 Woodland Road			
78	2316	1 Woodland Road			
79	2313	75 Belleville Avenue			
80	2304	37 Belleville Avenue			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/19/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
81	2302	27 Belleville Avenue			
82	2301	6 Belleville Avenue			DEAD END
83	2332	36 Smith Street			
84	2434	60 Rowe Street			
85	2433	28 Rowe Street			
86	2432	Rowe Street and Montgomery Street			
87	2421	173 Weaver Avenue			
88	2419	121 Weaver Avenue			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/20/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
89	2418	111 Weaver Avenue			
90	2618	16 Weaver Avenue			
91	2612	68 Franklin Street			
92	2711	335 Watsessing Avenue			
93	2710	307 Watsessing Avenue			
94	2709	283 Watsessing Avenue			
95	2707	259 Grove Street			
96	2704	205 Grove Street			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/21/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
97	2262	38 Broad Street			
98	2522	20 Broad Street			
99	1122	317 Glenwood Avenue			
100	1130	Henry Street at Glenwood Avenue			
101	1227	80 Prospect Street			
102	1237	20 Prospect Street			
103	1247	48 Olive Street			
104	1401	JFK Drive North (corner of Willow Street)			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/22/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
105	1408	7 Hinrichs Place			
106	1405	21 Orange Street			
107	1402	Willow Street (opposite 22 Willow Street)			
108	1335	Orange St. Between Cross St & Home Depot			
109	1334	Cross St. Mid-Block bet. Orange & Charles St.			
110	1331	Cross Street at Charles St. & Ella St.			
111	1423	Ella Street at Cross Street			
112	1324	Home Depot Parking Lot at walkway			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/23/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
113	1322	Orange Street at Orange Place			
114	1312	171 Orange Street			
115	1422	Watsessing Avenue at Ella Street			
116	1427	71 Watsessing Avenue			
117	1430	Arlington Avenue at Watsessing Ave.			
118	1431	Arlington Avenue at MacArthur			
119	1435	Between Federal Plaza & RR Bridge			
120	1440	130 Arlington Avenue			

LARGE DIAMETER WATERMAIN FLUSHING SEQUENCE
2022 PROGRAM
5/24/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
113	1322	Orange Street at Orange Place			
121	1442	151 Floyd Avenue			
122	1526	97 Floyd Avenue			
123	1529	471 Beardsley Avenue			
124	1505	282 North 17th Street			
125	1552	Ampere Parkway & Beardsley Avenue			