

## HALOACETIC ACID (HAA5) AND TRIHALOMETHANE (TTHM) COMPLIANCE

### SECOND QUARTER 2020

This is to inform our water customers that the Bloomfield Water Department is now **in compliance** with the EPA and NJDEP Requirements for the maximum levels of disinfection by-products or the chemicals known as Haloacetic Acids (HAA5) and Trihalomethanes (HAA5).

Please see the chart below for our current quarterly sampling.

<b>DISINFECTION BY PRODUCTS ANNUAL RUNNING AVERAGE</b>						
<b>BLOOMFIELD WATER DEPARTMENT - PWSID 0702001</b>						
<b>2nd QUARTER 2020</b>						
TTHM < 0.080 mg/L or 80 µg/L						
	THIRD QUARTER 2019	FOURTH QUARTER 2019	FIRST QUARTER 2020	SECOND QUARTER 2020	AVERAGE	COMMENTS
LOCATION						
61 Bukowski Place	120	44	47	51	66	COMPLIANT
1409 Broad Street	102	37	43	38	55	COMPLIANT
127 Evans Road	103	33	46	37	55	COMPLIANT
25 Daka Court/321 Broughton Ave/81 Broughton	108	37	43	42	58	COMPLIANT
HAA5 < 0.060 mg/L or 60 µg/L						
	THIRD QUARTER 2019	FOURTH QUARTER 2019	FIRST QUARTER 2020	SECOND QUARTER 2020	AVERAGE	COMMENTS
LOCATION						
61 Bukowski Place	50	49	54	51	51	COMPLIANT
1409 Broad Street	81	48	54	44	57	COMPLIANT
127 Evans Road	72	41	53	27	48	COMPLIANT
25 Daka Court/321 Broughton Ave/81 Broughton	75	47	51	29	51	COMPLIANT