

## HALOACETIC ACID (HAA5) AND TRIHALOMETHANE (TTHM) COMPLIANCE

### THIRD QUARTER 2020

This is to inform our water customers that the Bloomfield Water Department remains **in compliance** with the EPA and NJDEP Requirements for the maximum levels of disinfection by-products or the chemicals known as Haloacetic Acids (HAA5) and Trihalomethanes (TTHM).

Please see the chart below for our current quarterly sampling.

### DISINFECTION BY PRODUCTS ANNUAL RUNNING AVERAGE

#### BLOOMFIELD WATER DEPARTMENT - PWSID 0702001

#### 3rd QUARTER 2020

TTHM < 0.080 mg/L or 80 µg/L

	FOURTH QUARTER 2019	FIRST QUARTER 2020	SECOND QUARTER 2020	THIRD QUARTER 2020	AVERAGE	COMMENTS
LOCATION						
61 Bukowski Place	44	47	51	74	54	COMPLIANT
1409 Broad Street	37	43	38	67	46	COMPLIANT
127 Evans Road	33	46	37	65	45	COMPLIANT
25 Daka Court/321 Broughton Ave/81 Broughton	37	43	42	71	48	COMPLIANT

HAA5 < 0.060 mg/L or 60 µg/L

	FOURTH QUARTER 2019	FIRST QUARTER 2020	SECOND QUARTER 2020	THIRD QUARTER 2020	AVERAGE	COMMENTS
LOCATION						
61 Bukowski Place	49	54	51	25	45	COMPLIANT
1409 Broad Street	48	54	44	44	48	COMPLIANT
127 Evans Road	41	53	27	42	41	COMPLIANT
25 Daka Court/321 Broughton Ave/81 Broughton	47	51	29	33	40	COMPLIANT